

EC DECLARATION OF PERFORMANCE

According to EU Construction Products Regulation No. 305/2011

1. Unique Product Identification Code(s): NFXI-WCF-WC
2. Type Number(s): NFXI-WCF-WC
 Bases / Ancillaries
 - B501AP Mounting Base – Low profile base IP21C
 - WPW Deep back box, white
 - WRR Deep back box, Red
- Description: High output strobe with short circuit isolator
3. Intended Use: Fire detection and fire alarm systems installed in and around buildings
4. Manufacturer: KAC Alarm Company
 KAC House
 Thornhill Road
 North Moons Moat
 Redditch
 B98 9ND
 UK
5. Trading Company: Notifier by Honeywell
 Pittway Systems Technology Group Europe Limited
 Caburn House
 2B Brooks Road
 Lewes
 BN7 2BY
 UK
6. System of assessment: System 1
7. Notified Body: BRE Global Ltd
 Notified Body Number: 0832
 EC Certificate Number(s) 0832-CPR-F1212
8. European Technical Assessment Reference: Not Applicable
9. Declared Performance:

EN 54-23: Fire Detection and Fire Alarms Systems – Visual Alarm Devices		
Clause	Essential Characteristic	Performance
4.2.1	Duration of operation	Pass
4.2.2	Provision for external conductors	Pass
4.2.3	Flammability of materials	Pass
4.2.4	Enclosure protection	Pass
4.2.5	Access	Pass
4.2.6	Manufacturer's adjustments	Pass
4.2.7	On site adjustments of behaviour	Pass
4.2.8	Requirements for software controlled devices	Pass
4.3.1	Coverage volume	Pass – Cat C and W
4.3.2	Variation of light output	Pass
4.3.3	Minimum and maximum effective luminous intensity	Pass
4.3.4	Light colour	Pass
4.3.5	Light temporal pattern and frequency of flashing	Pass
4.3.6	Marking and data	Pass
4.3.7	Synchronization (option with requirements)	Pass
4.4.1	Temperature resistance	Pass
4.4.2	Humidity resistance	Pass
4.4.3	Shock and vibration resistance	Pass
4.4.4	Corrosion resistance – Sulphur dioxide (SO ₂) corrosion (endurance)	Pass
4.4.5	Electrical stability – EMC, immunity (operational)	Pass

EN 54-17: Fire Detection and Fire Alarms Systems - Short Circuit Isolators		
Clause	Description	Performance
4.2.	Integral status indication	Pass
4.3.	Connection of ancillary devices	Pass
4.4.	Monitoring of detachable short circuit isolators	Pass
4.5.	Manufacturer's adjustments	Pass
4.6.	On site adjustments	Pass
4.7.	Marking	Pass
4.8.	Data	Pass
4.9.	Additional requirements for software controlled short circuit isolators	Pass
5.1.5	Functional Tests	Pass
5.2	Reproducibility	Pass
5.3	Variation in supply voltage	Pass
5.4	Dry heat (operational)	Pass
5.5	Cold (operational)	Pass
5.6	Damp heat cyclic (operational)	Pass
5.7	Damp heat steady state (endurance)	Pass
5.8	Sulphur dioxide (SO ₂) corrosion (endurance)	Pass
5.9	Shock (operational)	Pass
5.10	Impact (operational)	Pass
5.11	Vibration, sinusoidal (operational)	Pass
5.12	Vibration, sinusoidal (endurance)	Pass
5.13	EMC immunity	Pass

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4

Signed For and on behalf of
KAC ALARM COMPANY:

[Handwritten Signature]

KAC Alarm Company Limited

Name:

[Handwritten Name]

KAC House

Function:

[Handwritten Function]

**Thornhill Road
North Moons Moat**

Date and Place of issue:

[Handwritten Date]

**Redditch
B98 9ND**