

## Certificate of Product Approval

Certificate Number: 928j-(cl-6)

Issue: 02

### Sterling Safety Systems Ltd

Unit B12a  
Holly Farm Business Park  
Honiley  
Warwickshire  
CV8 1NP  
United Kingdom



is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Heat Detectors

HFV-TA-01  
HFV-TA-05

(refer to Appendix for details)

#### Standards

EN 54-5:2000 + A1:2002  
EN 54-25:2008

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

28 June 2017

Date of Issue

25 August 2011

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX

T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 928j-(cl-6)

Issue: 02

### Sterling Safety Systems Ltd

| Certified Product | Description   | LPCB Ref.No. |
|-------------------|---|--------------|
| HFW-TA-01         | Wireless Heat Detector (WAB100 Base)<br>Notes:<br>1. Meets the requirements of EN 54-5 for Class A1R<br>2. The device must be used with the following batteries only:<br>CR123A (3 Vdc) - Main Battery<br>CR2032A (3 Vdc) - Secondary Battery               | 928j/01      |
| HFW-TA-05         | Wireless Libra Addressable Class P Heat Detector (WAB100 Base)<br>Notes:<br>1. Meets the requirements of EN 54-5 for Class A1R and BS<br>2. The device must be used with the following battery type only:<br>CR123A (3 Vdc) - Primary and Secondary Battery | 928j/02      |

#### Bases

WAB100 Wireless Adaptor Base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan  
Verifier

28 June 2017  
Date of Issue

25 August 2011  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)  
LPCB is a Registered Trademark of the Building Research Establishment Ltd.


