

CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE



Declaration of performance

DOP-0001 issue A

- | | |
|---|--|
| 1. Unique identification code of the product-type: | 3-87 Doormouse Series |
| 2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR: | 3-87-0351 to 3-87-0399 inclusive and
3-87-0551 to 3-87-0599 inclusive |
| 3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer: | For use on fire and smoke
compartmentation doors |
| 4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5): | Stephenson Gobin Ltd, 20 Longfield Road,
South Church Enterprise Park,
Bishop Auckland, DL14 6XB, England |
| 5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2): | N/A |
| 6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V: | System 1 |
| 7. In case of the declaration of performance concerning a construction product covered by a harmonized standard: | EN 1155: 1997: A1: 2002
Warrington Certification Ltd 1121
1121-CPD-AE0011 |
| 8. European Technical Assessment: | N/A |
| 9. Declared performance | See table on following page |
| 10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. | See table on following page |


9. Declared performance

Essential characteristics	Performance	Harmonised technical specification
5.2.1 General	Size 6 closer, 120 Kg door and Size 3 closer, 60 Kg door.	EN 1155: 1997: A1: 2002
5.2.2 Electrical release	Pass	
5.2.3 Door closer requirements	Not applicable	
5.2.4 Durability	Pass (50,000 test cycles)	
5.2.5 Angle of hold	Pass	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	Pass (60 Kg and 120 Kg door)	
5.2.9 Delayed release	Not applicable	
5.2.11 Temperature rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire door suitability	Pass	
5.1.14.1 Corrosion resistance	Grade 3 (96 hours)	
5.1.14.2 Corrosion resistance	Pass	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



N. Goddard, Innovation Manager

1st July 2013
Bishop Auckland